




noel griffith, jr.
& associates
architects

Boys and Girls Club
Multi-Purpose Bldg.
Addendum Number One
February 15, 2013


Drawing Notes:

1. Sheet A6, Wall Sections: Install Tyvek, or equal, moisture barrier on all sheathing behind masonry.
2. Sheet A6, Wall Sections: Reference for 1" rigid insulation shall apply to all walls with masonry. Insulation shall be Styrofoam SM Brand, or equal.
3. Sheet A6, Wall Sections: Install continuous through-wall flashing with weep holes every 32" at horizontal masonry joint at floor level, and below rowlock course at top of masonry. See attached Sheet AD-1 for top of masonry detail. Install galvanized steel joint reinforcement at 16" o.c. in masonry veneer.
4. Sheet A6, Room Finishes: Exposed concrete floors shall have two coats of a curing and sealing compound applied. Product shall be Dayton Superior Cure and Seal 1315 EF, or approved equal.
5. Sheet A2, Court Layout Plan: Court lines will be vinyl tape in lieu of painted. Tape shall be solid vinyl marking tape by Pro-Line Safety Products, Inc., or equal.



PREFIN. FLASHING DIM'S.

SCALE: 3" = 1'-0"



TOP OF MASONRY DETAIL

SCALE: 1-1/2" = 1'-0"

FEB. 11, 2013


**noel griffith, jr.
& associates
architects**
 CHEYENNE, WYOMING (307) 632-2705

**MULTI-PURPOSE BLDG.
BOYS AND GIRLS CLUB**
 CHEYENNE, WYOMING

AD1