

## ADDENDUM NUMBER 2

### TOWN OF PINE BLUFFS CITY PARK IMPROVEMENTS

January 15, 2013



Erin M. Gates, P.E.

BenchMark Engineers, P.C.

Addendum Number 2 applies to the Town of City Park Improvements project.

1. Reminder: This project will be awarded as one contract. There will not be a separate contract for the electrical work, site work, etc.
2. Coordination for the Cable TV will be clarified with the selected Contractor. No cost for this work shall be included with the bid prices.
3. Clarification: 4" Crushed Base, Grading "W" shall be placed under the 4" concrete sidewalk, rather than as shown in the detail on C-100. There will be no separate measurement or payment for the base material per the special provisions for Section 02776.
4. The quantity for sidewalk has been revised, use the attached revised bid sheet for bidding.
5. Additional info for offloading is included with the attached diagram from BMS. Any notation of Owner on this sheet shall be disregarded.
6. The shelter may be shipped separate from building. The total weight for the shelter knocked down is approximately 40,000 lbs.
7. The internal plumbing of the pre-fabricated building will be completed by the manufacturer. The Contractor is responsible for connecting/final hook up of all lines.
8. The pre-fabricated building supplier will be furnishing: the building and the shelter. The Contractor shall be responsible for site preparations, design and installation of piers, off loading and setting the building, meters, disconnects, hook-up of all utilities, labor for installing the shelter above the restroom building, labor for restroom building installation, utility service lines, roof penetrations, arrangement for the crane, welding the restroom building to the piers, cleaning the building, touch-up paint, repairs from shrink wrap and all other work necessary for the installation of the building as described in the bid documents.
9. On Page 10, Section 2, Item c of the electrical information is changed to the following: "The lump sum price submitted by the Bidder for the schedule of work shall include a 1% margin to cover minor changes in work, differences in interpretations of the Bidding Documents, discrepancies in Staking Sheets and Drawings."

**Note: All bidders must acknowledge receipt of this addendum with the submittal of their bid.**

**END OF ADDENDUM NUMBER 2**