



Matthew H. Mead
Governor

Wyoming Department of Transportation

"Providing a safe, high quality, and efficient transportation system"

5300 Bishop Boulevard
Cheyenne, Wyoming 82009-3340



John F. Cox
Director

ADDENDUM NO. 2

TO: ALL PROSPECTIVE BIDDERS

FROM: HANS F. HEHR, CPPB
PROCUREMENT SERVICES MANAGER

SUBJECT: BID NO. 12-208HH – SALT/SAND BUILDING – SOUTH PASS, WYOMING
BID OPENING DATE AND TIME: JUNE 7, 2010 AT 11:00 A.M.

DATE: MAY 30, 2012

PLEASE MAKE THE FOLLOWING CHANGE(S) TO THE ABOVE REFERENCED BID:

- Please incorporate the attached page as it will now become a part of this bid.

Proposers are hereby required to acknowledge receipt of this addendum on their proposal or by facsimile, or electronic mail **OR THEIR PROPOSAL WILL NOT BE CONSIDERED.** Facsimiles or electronic mail must be received in the office of the Procurement Services Manager prior to the bid opening date and time.

Any questions concerning this addendum should be directed to Hans F. Hehr, at Telephone No. (307) 777-4106, Fax No., (307) 777-4755 or at the following e-mail address: hans.hehr@wyo.gov.



1001 12th Street
Gody, WY 82901
Tel: (307) 587-8848
Fax: (307) 587-8366

4020 Dewar Drive, Suite A
Rock Springs, WY 82901
Tel: (307) 352-2954
Fax: (307) 352-2956

189 North Main, Suite 112
Driggs, ID 83422
Tel: (208) 354-8036
Fax: (208) 354-8037

ADDENDUM NUMBER TWO

Project: South Pass Salt & Sand Building
South Pass, Wyoming
Architect's Project No: 1123

Owner: Wyoming Department of Transportation
5300 Bishop Boulevard
Cheyenne, Wyoming
Addendum Number: Two

Bid Date: June 7, 2012
Addendum Date: May 29, 2012

Time: 11:00 A.M. at the Office of Procurement Services Manager
5300 Bishop Boulevard, Cheyenne, Wyoming

IT IS INTENDED THAT BIDS SUBMITTED ARE BASED ON THE INCLUSION OF ALL ADDENDA. PLEASE ATTACH ALL ADDENDA TO THE SPECIFICATIONS AND ACKNOWLEDGE RECEIPT OF SAME IN THE DESIGNATED PLACE ON THE BID FORM.

PART ONE – DRAWINGS

1. Sheet E1.0

- a. Flag Notes: Flag Note 1 – Change to read: Fixture "A" to be a Hi-Bay Fluorescent with cold weather ballast, 6 lamp, acrylic prismatic lens with gasketed door. 3500K lamps, chain mount from structure. Metalux P/N; ABI-6545T5-N-UNV-L5835-EBTL3/3-HBAYC-CHAIN/SET/U.

END OF ADDENDUM NUMBER TWO