

**THE CONSTRUCTION INDUSTRY'S ONLINE DATA NETWORK**

[Home](#) [Projects](#) [Industry Directory](#) [My Account](#)

[Find My Projects](#) [Results](#)

Project Number  contains

**Find Projects**

Post Date/Time	Category	Name	Bid Date/Time	City	County	St	Owner	Solicitor
06/24/11 1	Bridge Replacement or Rehabit	TUNNEL ROAD BRIDGE REPLAC	07/28/11 03:00 PM	Rural	Albany	WY	Albany County, Wyoming	Albany County

Records from 1 to 1 of 1

**Date:** July 14, 2011

**To:** All Bidders for the:  
**TUNNEL ROAD BRIDGE REPLACEMENT PROJECT**

**From:** William Gorman, P.E.  
County Engineer  
Albany County, Wyoming

**Subject:** **ADDENDUM NUMBER 2**

By listing this Addendum by number and date in the space provided on the Proposal Form, the Bidder acknowledges that the Proposal submitted on this Project is in accordance with the stipulations set forth herein. Failure to list this Addendum on the Proposal Form may be cause for the rejection of the Bidder's Proposal.

The Bidding Documents for the above Project which include the Drawings and Specifications are hereby changed as follows:

**CHANGE OF COMPLETION DATE:**

**The completion date has been changed to May 12, 2012.**

**The completion date should be changed at the following locations in the bid documents:**

**Instructions to Bidders: Page 6, paragraph 2.**  
**Agreement: (sample) Page 24, Section 4.02.**

**Special Provision SP-1**

**General Notes:**

**ADD the following note:**

**17. The new bridge may be opened to traffic with an approved 12 ft wide temporary surface in place. A temporary surface may consist of material approved by the Engineer, such as timber planks, steel plates or gravel. Any temporary surface shall be completely removed prior to paving of the deck. Placing and removing of the temporary surface and associated traffic control will be considered subsidiary to other items and will not be measured for payment.**

**Section 02512 Plant Mix Pavements, 3.02**

**REPLACE paragraph B with:**

**Plant Mix Pavement may be placed when conditions are suitable, as defined elsewhere in the specifications.**

Feel free to contact me at 761-4800 or at [bill@gormanengineering.com](mailto:bill@gormanengineering.com) with any questions.